



Fraunhofer

TESTED[®] DEVICE

N.Y.R. Limited Partnership
BSL-3 Cleanroom Laboratory
Report No. NY 0909-495

DUPLICATE

Qualification Certificate

This is to certify that the cleanroom laboratory mentioned below by the company

N.Y.R. Limited Partnership

159/21 Charansanitwong Rd., Bangbumru
Bangplad, Bangkok 10700
Thailand

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number NY 0909-495.

The BSL-3 Cleanroom Laboratory at the Center of Emerging and Re-Emerging Infectious Diseases in Animals Faculty of Veterinary Science, Chulalongkorn University, Bangkok, Thailand in operation is fulfilling the specifications of Air Cleanliness Class 7 according to ISO 14644-1.

The cleanroom is limited usable. Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

The validity of this certificate applies only to the above mentioned tested object in this particular condition. For further information visit our website at www.ipa-qualification.com.

Stuttgart, Germany, December 9, 2009

i. A. 
Project manager