



Fraunhofer

TESTED DEVICE

Cleanroom Laboratory
Report No. NY 0003-170

IPA Certificate of Qualification

This is to certify that

N.Y.R. Limited Partnership

159 Charansanitwong Rd.
Bangkok 10700, Thailand

holds Certificate No. NY 0003-170.

The cleanroom laboratory installed by N.Y.R. Limited Partnership at the Faculty of Medicine, Siriraj Hospital, Bangkok, is suitable for operations that are depending on a P3 laboratory according to guideline M 057 BG Chemie. The above mentioned cleanroom laboratory is fulfilling the specifications of Cleanliness Class 100.000 (according to US Fed. Standard 209E).

For details see report at Fraunhofer IPA or above mentioned certified company.

Originally certified April 26th, 2000.

This certificate does not expire. To check its validity visit our website at <http://www.ipa-qualification.com>

Stuttgart, April 26th, 2000.

Signature of person responsible



Fraunhofer Institut
Produktionstechnik und
Automatisierung