



Fraunhofer

**TESTED[®]
DEVICE**

KUKA Deutschland GmbH
KMRiisy CR

Report No. KU 2302-1396

DUPLICATE

Statement of
Qualification

Single product
Electrostatic
Charge Behavior

Customer	KUKA Deutschland GmbH Zugspitzstrasse 140 86165 Augsburg Germany
Component tested	
Category:	Automation Components
Subcategory:	Robotics
Product name:	KMRiisy CR (manufacturing date: 4/12/2023; article number: 16010348; serial number: 1041360)

Measurement of charge behavior	
Standards/Guidelines:	SEMI E78-0222 The norms stated generally refer to the version valid at the time of the tests.
Test devices:	<ul style="list-style-type: none">Data capture:.....Influence-E-Fieldmeter, type EMF58 Eltex-Elektrostatik-GmbH
Test environment parameters:	<ul style="list-style-type: none">Cleanroom Air Cleanliness Class (according to ISO 14644-1):..... ISO 1Airflow velocity:.....0.45 m/sAirflow pattern:..... vertical laminar flowTemperature:.....22 °C ± 0.5 °CRelative humidity: 45 % ± 5 %
Test procedure parameters:	<ul style="list-style-type: none">Tool weight:no tool was mountedMotion sequence: representative operationVelocity: 80 % of maximum velocityAcceleration:.....0.3 m/s²Deceleration:..... -0.3 m/s²Attached payload:.....m = 200 kgCapacity/Utilization:87,66 % of maximum capacity

Test result / Classification	The robot KMRiisy CR fulfills the permissible limit values of 8.5V/cm (0.85 kV/m) for the sensitivity threshold 2033/7.7 nm / 2010/45 nm according to SEMI E78-0222.
------------------------------	--

Electrostatic field			
Electrostatic level		Test result	
Year Node	limit value [V/cm]	mean value [V/cm]	max. single value measured [V/cm]
2033 7.7 nm	8.5	5	10
Limit value (except the vicinity ¹⁾ of the Wi-Fi antenna):		fulfilled	
2010 45 nm	50	31	100
Limit value (in the vicinity ¹⁾ of the Wi-Fi antenna):		fulfilled	

¹⁾sphere with a radius of ≤ 305 mm around the antenna

Note: The instructions given in the user documentation from KUKA Deutschland GmbH must be observed. Only dissipative may be used in the handling area. It is best to do without a sticker on the product in the handling area.

The measuring devices used for the qualification tests are calibrated at regular intervals; their results can be traced back to national and international standards. In cases where no national standards exist, the test procedure implemented complies with the technical regulations and norms applicable at the time of the test. The relevant documentation can be viewed on request at any time.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

Fraunhofer Institute for Manufacturing Engineering and Automation IPA	KU 2302-1396 Report No. first document	Stuttgart, December 14, 2023 Place, date of first document issued
Department of Ultraclean Technology and Micromanufacturing	-- Report No. current document	-- Place, current date
Nobelstrasse 12 70569 Stuttgart Germany	on behalf of Dr.-Ing. Frank Bürger, Project Manager Fraunhofer IPA	