



**Fraunhofer**

**TESTED<sup>®</sup>  
DEVICE**

Knauf Ceiling Solutions  
Armstrong Perla dB 19 mm  
**Report No. KN 2101-1202**

DUPLICATE

Statement of  
Qualification

Single product  
Particle Emission

Statement of Qualification · Single product

Customer	Knauf Ceiling Solutions GmbH & Co. KG Elsenthal 15 94481 Grafenau Germany
Component tested	
Category:	Cleanroom Facilities
Subcategory:	Wall/Ceiling/Floor/Door
Product name:	Armstrong Perla dB 19mm (manufacturing date: 10/15/2020; article number: BP3191; dimension: 600x600x 19mm)
Random sampling of particle emissions (airborne) at representative sites	
Standards/Guidelines:	ISO 14644-1, -14 The norms stated generally refer to the version valid at the time of the tests.
Test devices:	Optical particle counter: LasAir II 110 and LasAir III 110 with measuring ranges $\geq 0.1\text{ }\mu\text{m}$ , $\geq 0.2\text{ }\mu\text{m}$ , $\geq 0.3\text{ }\mu\text{m}$ , $\geq 0.5\text{ }\mu\text{m}$ , $\geq 1.0\text{ }\mu\text{m}$ and $\geq 5.0\text{ }\mu\text{m}$
Test environment parameters:	<ul style="list-style-type: none"><li>Cleanroom Air Cleanliness Class (according to ISO 14644-1):..... ISO 1</li><li>Airflow velocity:.....0.45 m/s</li><li>Airflow pattern:..... vertical laminar flow</li><li>Temperature: .....22 °C <math>\pm</math> 0.5 °C</li><li>Relative humidity: ..... 45 % <math>\pm</math> 5 %</li></ul>
Test procedure parameters:	The ceiling system was subjected to stress as follows: <ul style="list-style-type: none"><li>Structure-borne noise: ..... approx. 5 to 50 Hz</li><li>Oscillation velocity (<math>\varnothing</math>):.....v = 0.7247 mm/s</li><li>Oscillation acceleration (<math>\varnothing</math>):.....a = 0.0194 m/s<sup>2</sup></li><li>Deflection of the system (<math>\varnothing</math>):..... s = 0.1419 mm</li></ul>

**Test result / Classification**

When operated under the specified test conditions, the ceiling system Armstrong Perla dB 19mm is suitable for use in cleanrooms fulfilling the specifications of the following Air Cleanliness Class according to ISO 14644-1:

Test parameter(s)	Air Cleanliness Class
Structure-borne noise = approx. 5 to 50Hz	4
Overall result	

It should be noted that cleanrooms of class 1 to 5 according to ISO 14644-1 have a higher filter occupancy, which may restrict the use of ceiling systems. Cleanrooms with a horizontal displacement flow form an exception to this.

The test result may be affected by the surrounding ceiling system, in particular the material pairing between lights and ceiling frames, as well as other mounting accessories. Particle emission behavior should be reassessed in each assembly situation.

Please note: Transport damages, incorrect installation, aging behavior, corrosion etc. can influence the test result.

The measuring devices used for the qualification tests are calibrated at regular intervals; their results can be traced back to national and international standards. In cases where no national standards exist, the test procedure implemented complies with the technical regulations and norms applicable at the time of the test. The relevant documentation can be viewed on request at any time.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

Fraunhofer Institute for Manufacturing Engineering and Automation IPA	KN 2101-1202 Report No. first document	Stuttgart, March 29, 2021 Place, date of first document issued
Department of Ultraclean Technology and Micromanufacturing	-- Report No. current document	-- Place, current date
Nobelstrasse 12 70569 Stuttgart Germany	on behalf of Dr.-Ing. Frank Bürger, Project Manager Fraunhofer IPA	