





Fraunhofer TESTED® DEVICE Knauf Ceiling Solutions Thermatex dB Acoustic Report No. KN 2405-1523

Statement of Qualification

Single product Particle Emission

Statement of Qualification • Single product

Customer

Knauf Ceiling Solutions GmbH & Co. KG Elsenthal 15 94481 Grafenau Germany

Test result/Classification

Test parame

Overall res

Please note: Transport damages, incorrect installation, aging behavior, corrosion etc. can influence the test result.

Component tested

Category:	Cleanroom Facilities
Subcategory:	Wall/Ceiling/Floor/Door
Product name:	Thermatex dB Acoustic (manufacturing date: 8/16/2024; color: white; article number: 713606; batch number: GR-L-11-01; size: 1200 x 1200 x 30 mm; grid system: KCS T 24)

Random sampling of particle emissions (airborne) at representative sites under atmospheric conditions

Standards/Guidelines:	ISO 14644-1, -14 The norms stated generally refer to the version valid at the time of the tests.	
Test devices:	Optical particle counter: LasAir II 110 and LasAir III 110 with measuring ranges \geq 0.1 µm, \geq 0.2 µm, \geq 0.3 µm, \geq 0.5 µm, \geq 1.0 µm and \geq 5.0 µm	
Test environment parameters:	 Cleanroom Air Cleanliness Class (according to ISO 14644-1):	
Test procedure parameters:	The ceiling system was subjected to stress as follows: • Structure-borne noise: • Oscillation velocity (Ø): • Oscillation acceleration (Ø):	

• Deflection of the system (Ø):.....s = 0.1162 mm

The measuring devices used for the qualification tests are calibrated at regular intervals; their results can be traced back to national and international standards. In cases where no national standards exist, the test procedure implemented complies with the technical regulations and norms applicable at the time of the test. The relevant documentation can be viewed on request at any time.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

Fraunhofer Institute for Manufacturing Engineering and Automation IPA

KN 2405-1523 Report No. first document

Department of Ultraclean Technology and Micromanufacturing

Nobelstrasse 12 70569 Stuttgart Germany



Report No. current document



When operated under the specified test conditions, the ceiling system Thermatex dB Acoustic is suitable for use in cleanrooms fulfilling the specifications of the following Air Cleanliness Class according to ISO 14644-1:

eter(s)	Air Cleanlines Class	
rne noise = approx. 50Hz	4	
ılt		

It must be pointed out, that according to ISO 14644-1 cleanrooms classes 1 to 5 have a high filter occupancy, with the result that large-surface ceiling systems cannot be used in some cases. Cleanrooms with a horizontal displacement flow form an exception to this.

The test result may be influenced by the surrounding ceiling system, in particular the material pairing between the light and ceiling frame, as well as other assembly accessories. Particle emission behavior should be re-assessed in the respective assembly situation.

The cut edges/back are made of very porous material. Therefore, the use of the test piece in clean/hygienic areas is considered to be critical.

Stuttgart,	October	2,	2024	
------------	---------	----	------	--

Place, date of first document issued

Place,	current	date

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.