



valid until: October 2, 2029

Fraunhofer

TESTED[®] DEVICE

Knauf Ceiling Solutions
METAL Clip-in Rd1522
Report No. KN 2405-1523

Single product Particle Emission

Qualification Certificate

This is to certify that the product mentioned above, provided by

Knauf Ceiling Solutions GmbH & Co. KG
Grafenau, Germany

has been awarded a Fraunhofer certificate TESTED DEVICE
bearing the report number KN 2405-1523.

The ceiling system METAL Clip-in Rd1522 with Acoustic Fleece
(color: white) was assessed in compliance with ISO 14644-14.
When operated under the specified test conditions, it is suitable
for use in cleanrooms fulfilling the specifications of the following
Air Cleanliness Class according to ISO 14644-1:

Test parameter(s)	Air Cleanliness Class
Structure-borne noise = approx. 50Hz	1
Overall result	

It must be pointed out, that according to ISO 14644-1 clean-
rooms classes 1 to 5 have a high filter occupancy, with the result
that large-surface ceiling systems cannot be used in some cases.
Cleanrooms with a horizontal displacement flow form an excep-
tion to this. The test result may be affected by the surrounding
ceiling system.

Please note: Transport damages, incorrect installation, aging
behavior, corrosion etc. can influence the test result.

KN 2405-1523
Report No. first document

Stuttgart, October 2, 2024
Place, date of first document issued

--
Report No. current document

--
Place, current date

on behalf of 
Dr.-Ing. Frank B rger, Project Manager Fraunhofer IPA

This document only
applies to the named
product in its original state
and is valid for a period of
5 years from the date the
first document was issued.
The document can be
verified under
www.tested-device.com.

Detailed information and
parameters of the test
environment can be found
in the Fraunhofer IPA test
report.