



Tremco CPG Europe  
Report No. TR 2501-1581

# Cleanroom<sup>®</sup> Suitable Materials

Peran ESD SL20

Outgassing Behavior VOC/SVOC  
ISO-ACC<sub>m</sub> Class -6.9 / -5.8

## FLOORING & COATING

Single product  
Outgassing Behavior  
VOC/SVOC

## Qualification Certificate

We hereby certify that the material stated above, provided by

Tremco CPG Europe  
Bodenwoehr, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number TR 2501-1581.

The outgassing behavior of Peran ESD SL20 (color: 2012, RAL7040) at the stated temperature was investigated according to VDI 2083 Part 17, ISO 14644-15 and ISO 16000-25. Based on the outgassing rates determined for the specific surfaces, the following material classification was made for the corresponding Contaminant Category:

Contaminant Category (x)	SER <sub>a</sub> <sup>1)</sup> 23 °C [g/m <sup>2</sup> s]	ISO-ACC <sub>m</sub> Class (x) based on 23 °C
VOC	1.2 x 10 <sup>-7</sup>	<b>-6.9</b>
SVOC	1.6 x 10 <sup>-6</sup>	<b>-5.8</b>
Sum of VOC and SVOC	1.8 x 10 <sup>-6</sup>	--
Refractories <sup>2)</sup>	7.4 x 10 <sup>-10</sup>	--
Siloxanes <sup>3)</sup>	7.4 x 10 <sup>-10</sup>	--

SER: Area-specific emission rate

<sup>1)</sup> The emission rate is calculated using the detected mass based on the response of the standard, the analyzed sample surface area or number of samples and the sampling duration.

<sup>2)</sup> Refractories are compounds containing elements other than C, H and O (e.g.: S, P, N...).

<sup>3)</sup> Siloxanes and other Si-containing organic substances. Siloxanes also count as refractories.

TR 2501-1581  
Report No. first document

Stuttgart, May 22, 2025  
Place, date of first document issued

--  
Report No. current document

--  
Place, current date

on behalf of   
Dr.-Ing. Frank Bürger, head of business unit Testing and Certification

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under [www.tested-device.com](http://www.tested-device.com).

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.