



Tremco CPG Europe  
Report No. TR 2501-1581

# Cleanroom<sup>®</sup> Suitable Materials

Flowcoat SF41LE  
Biological Resistance: good

## FLOORING & COATING

### Single product Biological Resistance

### Qualification Certificate

We hereby certify that the material stated above, provided by

**Tremco CPG Europe**  
Bodenwoehr, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number TR 2501-1581.

The biological resistance of the Flowcoat SF41LE (color: 280, Mid Gray) regarding to growth intensity was investigated in accordance with ISO 846 and classified with the following result:

Biological resistance	Growth intensity	Classification
Procedure A (resistance to fungi)	1	good
Procedure C (resistance to bacteria)	1	good
Overall result	good	

The classification is based on a worst-case consideration of the Procedures A and C.

TR 2501-1581  
Report No. first document  
--  
Report No. current document

Stuttgart, May 16, 2025  
Place, date of first document issued  
--  
Place, current date

on behalf of   
Dr.-Ing. Frank Bürger, head of business unit Testing and Certification

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under [www.tested-device.com](http://www.tested-device.com).

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.