



Tremco CPG Europe
Report No. TR 2501-1581

Cleanroom[®] Suitable Materials

Flowfresh ESD SL
Biological Resistance: weak

FLOORING & COATING

Single product Biological Resistance

Qualification Certificate

We hereby certify that the material stated above, provided by

Tremco CPG Europe
Bodenwoehr, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number TR 2501-1581.

The biological resistance of the Flowfresh ESD SL (color: gray) regarding to growth intensity was investigated in accordance with ISO 846 and classified with the following result:

Biological resistance	Growth intensity	Classification
Procedure A (resistance to fungi)	2	weak
Procedure C (resistance to bacteria)	1	good
Overall result	weak	

The classification is based on a worst-case consideration of the Procedures A and C.

TR 2501-1581
Report No. first document
--
Report No. current document

Stuttgart, May 16, 2025
Place, date of first document issued
--
Place, current date

on behalf of 
Dr.-Ing. Frank Bürger, head of business unit Testing and Certification

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.