



Fraunhofer

TESTED[®] DEVICE

SIMON
TORTUGA

Report No. SI 2505-1628

Single product
Particle Emission
in Cleanroom
(atmospheric)

Qualification Certificate

This is to certify that the product mentioned above, provided by

SIMON S.A.U.
Barcelona, Spain

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number SI 2505-1628.

The luminaire TORTUGA (color: white) was assessed in compliance with ISO 14644-14. When operated under the specified test conditions (room temperature: $22^{\circ}\text{C} \pm 0.5^{\circ}\text{C}$; relative humidity: $45\% \pm 5\%$), it is suitable for use in cleanrooms fulfilling the specifications of the following Air Cleanliness Class according to ISO 14644-1:

Test parameter(s)	Air Cleanliness Class
Structure-borne noise = approx. 50Hz	1
Overall result	

It should be noted that cleanrooms of Class 1 to 5 according to ISO 14644-1 have a higher filter occupancy, which may restrict the use of panel lighting systems. Cleanrooms with a horizontal displacement flow form an exception to this. The test result may be affected by the surrounding ceiling system.

Please note: Transport damages, incorrect installation, aging behavior, corrosion etc. can influence the test result.

SI 2505-1628

Report No. first document

Stuttgart, July 1, 2022

Place, date of first document issued

--

Report No. current document

--

Place, current date

on behalf of

Dr.-Ing. Frank Bürger, head of business unit Testing and Certification

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued.

The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.



Fraunhofer
IPA