



LEONHARD WEISS FT
Report No. LE 2405-1521

Cleanroom[®] Suitable Materials

LW-Terrazzo

H₂O₂ Absorption/Desorption:
fast

FLOORING & COATING

Single product Hydrogen Peroxide Absorption/Desorption

Qualification Certificate

We hereby certify that the material stated above, provided by

LEONHARD WEISS FT
Göppingen, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number LE 2405-1521.

The hydrogen peroxide absorption/desorption of LEONHARD WEISS Terrazzo (color: white/blue) was investigated at the stated test parameters, providing the following test result according to VDI 2083 Part 20:

| Ø k-value [min] | Standard deviation [min] | Classification |
|--------------------|-----------------------------|----------------|
| 7.37 | 0.64 | fast |

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

LE 2405-1521
Report No. first document
--
Report No. current document

Stuttgart, July 4, 2025
Place, date of first document issued
--
Place, current date

on behalf of 
Dr.-Ing. Frank Bürger, head of business unit Testing and Certification