



SHERWIN-WILLIAMS UK Ltd
Report No. SH 2602-1725
Cleanroom (atmospheric)

Cleanroom[®] Suitable Materials

Resutile HTS

**H₂O₂ Absorption/Desorption:
fast**

FLOORING

Single product
**Hydrogen Peroxide
Absorption/Desorption**

Qualification Certificate

We hereby certify that the material stated above, provided by

SHERWIN-WILLIAMS UK LIMITED
Witney, United Kingdom

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number SH 2602-1725.

The hydrogen peroxide absorption/desorption of Resutile HTS (color: light gray) was investigated at the stated test parameters,

providing the following test result according to VDI 2083 Part 20:

Ø k-value [min]	Standard deviation [min]	Classification
11.76	0.89	fast

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

The norms stated generally refer to the version valid at the time of the tests.

SH 2602-1725
Report No. first document

--
Report No. current document

Stuttgart, July 31, 2026
Place, date of first document issued

--
Place, current date

on behalf of 
Dr.-Ing. Frank Bürger, head of business unit Testing and Certification