



**SHERWIN-WILLIAMS UK Ltd**  
**Report No. SH 2602-1725**  
**Cleanroom (atmospheric)**

# Cleanroom<sup>®</sup> Suitable Materials

**Resutile SDS**  
**vs. reel PA6: ISO 3**  
**Particle Emission (flooring)**

## FLOORING

Single product  
**Particle Emission  
in Cleanroom  
(atmospheric)**

## Qualification Certificate

We hereby certify that the material stated above, provided by

**SHERWIN-WILLIAMS UK LIMITED**  
Witney, United Kingdom

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number SH 2602-1725.

The level of particulate contamination emitted during application of tribological stress on the material pairing in cleanroom (room temperature:  $22^{\circ}\text{C} \pm 0.5^{\circ}\text{C}$ ; relative humidity:  $45\% \pm 5\%$ ) specified lies within the permissible values of the corresponding Air Cleanliness Class in accordance with ISO 14644-1:

| Material pairing and test procedure                                                  |         | Suitable for Air Cleanliness Class |
|--------------------------------------------------------------------------------------|---------|------------------------------------|
| Resutile SDS (steel gray)                                                            | vs. PA6 | ISO Class: 3                       |
| Reel-on-disc test vs. PA6; normal force: 300 N<br>Type of friction: rolling friction |         |                                    |

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under [www.tested-device.com](http://www.tested-device.com).

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

The norms stated generally refer to the version valid at the time of the tests.

SH 2602-1725  
Report No. first document  
--  
Report No. current document

Stuttgart, July 31, 2026  
Place, date of first document issued  
--  
Place, current date

on behalf of   
Dr.-Ing. Frank Bürger, head of business unit Testing and Certification