



Gerflor
Report No. GE 2105-1233

Cleanroom[®] Suitable Materials

Mip. Biocontrol Clean
Particle (vs. PA6 Nylon): ISO 3

FLOORING & COATING

Single product Particle Emission

Qualification Certificate

We hereby certify that the material stated above, provided by

Gerflor Mipolam GmbH
Troisdorf, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number GE 2105-1233.

The level of particulate contamination emitted during application of tribological stress on the material pairing specified lies within the permissible values of the corresponding Air Cleanliness Class in accordance with ISO 14644-1:

Material pairing and test		Suitable for Air Cleanliness Class (ISO 14644-1)
Mipolam Biocontrol Clean (gray 5430)	vs. PA6	ISO Class: 3
Reel-on-disc test normal force: 300 N		

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under **www.tested-device.com**.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

GE 2105-1233
Report No. first document
--
Report No. current document

Stuttgart, September 20, 2021
Place, date of first document issued
--
Place, current date

on behalf of 
Dr.-Ing. Udo Gommel, Project Manager Fraunhofer IPA