



GERFLOR  
Report No. GE 2506-1641

# Cleanroom<sup>®</sup> Suitable Materials

DECOCLEAN

H<sub>2</sub>O<sub>2</sub> Absorption/Desorption:  
non-absorptive

## FLOORING & COATING

### Single product Hydrogen Peroxide Absorption/Desorption

### Qualification Certificate

We hereby certify that the material stated above, provided by

GERFLOR  
LYON, France

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number GE 2506-1641.

The hydrogen peroxide absorption/desorption of DECOCLEAN (color: chalk) was investigated at the stated test parameters, providing the following test result according to VDI 2083 Part 20:

Ø k-value [min]	Standard deviation [min]	Classification
2.89	0.67	non-absorptive

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under [www.tested-device.com](http://www.tested-device.com).

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

GE 2506-1641  
Report No. first document  
--  
Report No. current document

Stuttgart, July 11, 2025  
Place, date of first document issued

--  
Place, current date

on behalf of   
Dr.-Ing. Frank Bürger, head of business unit Testing and Certification